

Energy Performance Certificate (EPC) Scotland

Dwellings

167 ABERDOUR PLACE, BROUGHTY FERRY, DUNDEE, DD5 2PL

9607-1009-6204-1226-3204
RdSAP, existing dwelling
Elmhurst
Boiler and radiators, mains gas

Dwelling type: Mid-terrace house
Date of assessment: 10 April 2026
Date of certificate: 13 April 2026
Total floor area: 78 m²
Primary Energy Indicator: 263 kWh/m²/year


Reference number:
Type of assessment:
Approved Organisation:
Main heating and fuel:

You can use this document to:

- Compare current ratings of properties to see which are more energy efficient and environmentally friendly
- Find out how to save energy and money and also reduce CO₂ emissions by improving your home

Estimated energy costs for your home for 3 years*	£4,83	See your recommendations report for more information
Over 3 years you could save*	9	

* based upon the cost of energy for heating, hot water, lighting and ventilation, calculated using standard assumptions




Energy Efficiency Rating

1

This graph shows the current efficiency of your home, taking into account both energy efficiency and fuel costs. The higher this rating, the lower your fuel bills are likely to be.

Your current rating is **band D (62)**. The average rating for EPCs in Scotland is **band D (61)**.

The potential rating shows the effect of undertaking all of the improvement measures listed within your recommendations report.



Environmental Impact (CO₂) Rating

This graph shows the effect of your home on the environment in terms of carbon dioxide (CO₂) emissions. The higher the rating, the less impact it has on the environment.

Your current rating is **band D (63)**

The potential rating shows the effect of undertaking all of the improvement measures listed within your recommendations report.

Top actions you can take to save money and make your home more efficient

Recommended measures	Indicative cost	Typical savings over 3 years
1 Flat roof or sloping ceiling insulation	£900 - £1,200	£645.00
2 Floor insulation (suspended floor)	£5,000 - £10,000	£267.00
3 Increase hot water cylinder insulation	£20 - £40	£123.00

A full list of recommended improvement measures for your home, together with more information on potential cost and savings and advice to help you carry out improvements can be found in your recommendations report.

To find out more about the recommended measures and other actions you could take today to stop wasting energy and money, visit greenerscotland.org or contact Home Energy Scotland on 0808 808 2282.

THIS PAGE IS THE ENERGY PERFORMANCE CERTIFICATE WHICH MUST BE AFFIXED TO THE DWELLING AND NOT BE REMOVED UNLESS IT IS REPLACED WITH AN UPDATED CERTIFICATE